

LTEU SERIES USER MANUAL

Thank you for selecting this UPS. It provides you with better protection for connected equipments.

Please read this manual!

This manual provides safety, installation and operation instructions which will guide you to the best performance of your equipment.

Please save this manual!

It includes important instructions for the safe usage of the equipment and to obtain manufacturer's support in case of need.

Please keep or recycle the packaging materials!

Packaging materials used in our products are designed to provide protection from transportation. These materials are necessary in case that the equipment needs to be shipped back for service. Damage that may occur during the shipment is not covered by the product's warranty.

1. INTRODUCTION

1-1 System Description

The product is line interactive UPS with LED indicators, newest technology and powerful function. The line interactive UPS is designed with 2 steps boost and 1 step buck AVR to stabilize input voltage. Input voltage range is

-30%, +25%, but output regulation is +/- 10%. The line interactive UPS provides you with the ability of perfect protection for your critical devices.

1-2 Features

- Line interactive design.
- Microprocessor control guarantees high reliability.
- Frequency 50Hz/60Hz auto sensing.
- Equipped with 2 steps boost and 1 step buck AVR to stabilize Utility voltage.
- Built-in DC start function enable UPS to be started up without AC power supplied.
- UPS green mode (Energy saving function).
- Off mode charging.
- Modem / phone line surge protection.
- Over / low voltage, short circuit, lighting, surge (option) protection.

2. CAUTION


- The UPS contains voltage that is potentially hazardous. Qualified or certified technician should proceed all repairs and maintenance.
- The UPS has its own internal energy source (battery). The output receptacles may be active even when the UPS is not connected to the Utility.
- The UPS is suitable for computers and electronic equipment with substantial rectifier or capacitive loads, not suitable for electronic equipment with significant inductive loads such as motors and fluorescent lamps.
- Be sure to operate within the power rating of the UPS. Below 1/2 or 1/3 of the rated power is recommended for longer backup time and longer battery life.
- Do not place the UPS near excessive humidity, under sunshine or close to heat emitting sources.
- If the UPS is out of order, detach the power cord and consult your dealer right away. Do not

remove cover, there is no serviceable part inside.

- The unit should be supplied by a grounded source. Do not operate the unit without a ground source.
- The socket should be installed near the equipment and be easily accessible.
- Do not plug the UPS power cord into itself. That will result in a safety hazard.
- A qualified technician or electrician in accordance with local electrical code should perform installation.

3. INSTALLATION

The UPS must be installed in a protected environment away from heat emitting appliances such as a radiator or heater. Do not install this product where excessive moisture is present.




Caution: Never connect a laser printer or plotter to the UPS. A laser printer or plotter periodically draws significantly more power that its idle status, and may overload the UPS.

4. OVERVIEW

■ Front Panel


1. Main Power Switch: On/Off or Silence Button
2. On-Line LED: AC normal
3. Back-Up LED: Battery in backup
4. Cut-Off LED: Overload or Fault




■ Rear Panel

1. AC Input: Connect to input power cord
2. AC Fuse/ Circuit Breaker
3. Outlets
4. RJ-45/11
5. Communication Interface: USB port (Optional)


■ IEC-320




■ Standard Nema5-15R




■ UNIVERSAL R4



■ UNIVERSAL NEMA



■ GERMAN




5. OPERATION

- When the UPS is connected to the Utility, but UPS is not powered on, UPS will charge battery automatically and green LED display will flash every 2 seconds. Please press main switch on front panel for 1 second to turn on UPS.

- To turn off UPS when UPS is under AC mode, please press main switch on front panel for 4 seconds. To turn off UPS when UPS is under battery mode, press main switch and then UPS will shut down completely in 10 seconds.
- This UPS is designed with Off Mode charging, so UPS will charge battery continuously when UPS is under AC normal. If users intend to power off UPS completely, users have to plug out power cord from the Utility.
- Press on main switch for 4 seconds when the Utility is black out, UPS will be turned on and then go to back up mode. To turn off the UPS, please press main switch for 4 seconds again. If users want to turn on UPS again, please wait for 10 seconds to press main switch for 4 seconds again.
- When UPS is under battery mode and battery voltage is too high or too low, buzzer will beep.
- Buzzer will beep twice every 8 seconds when the Utility is black out. To silence alarm, please simply press main switch. To restart alarm, please press main switch again.

Storage Temperature	Recharge Frequency	Charging Duration
-15 - 30 ° C	Every 6 months	10 hours
30 - 45 ° C	Every months	10 hours



7. INDICATION

	Status	Y-LED	G-LED	Buzzer
Backup Mode	Battery normal, load normal	LED blinks twice per 4 seconds	Off	Beeping twice per 8 seconds
	No load (green mode only)	LED off firstly then blinks once per 4 seconds	Off	Beeping once per 4 seconds
	Low battery	LED blinks 4 times per second	Off	Beeping 4 times per second
	In phase lock (AC good, PLL working)	Off	LED blinks 4 times per second	Off

	Status	Y-LED	G-LED	R-LED	Buzzer
AC Normal Mode	Battery full	Off	Continuous On	Depend on fault condition	Off
	Battery charge 70% - 90%		Blink once per 8 seconds		
	Battery charge 50% - 70%		Blink once per 4 seconds		
	Battery charge 30% - 50%		Blink once per 2 seconds		
	Battery charge 0% - 30%		blink every second		

	Status	Y-LED	G-LED	R-LED	Buzzer
Off Mode	AC I/P disconnected (UPS OFF completely)	Off		Off	Off
	AC I/P normal (Battery in charging)	Off	Blink once per 2 seconds	Depend on fault condition	
	AC I/P normal (Battery fully charged)	Off	Off		
	UPS timer is set (through USB interface)	Blink once per 2 seconds	See G-LED status "AC normal mode" table		

	Status	Y-LED	G-LED	R-LED	Buzzer
Fault	Over temperature	Depends on AC I/P or load condition		Off	Beep 32 times per other 2 seconds
	Overload			Blink twice per second	Continuously beeping
	O/P short circuit			On	Beep 32 times per other 2 seconds

8. TROUBLE SHOOTING

Upon UPS failure, please kindly check UPS by following steps. If there is no problem with below points, please kindly send UPS for service.

- Is main power switch turned on?
- Is the UPS plugged into a working wall outlet?
- Is the line voltage within the rating specified?
- Is the fuse broken (at rear panel)?
- Is the UPS overload?
- Is the battery not fully charged?

Please provide the following information when call for service:

- Model number, serial number
- Date of the problem occurred, date of purchase

- Full description of the problem including load, LCD and alarm status, installation condition, working environment, etc.

UPS can not turn on LED not light	Battery voltage less than 10V	Recharge the battery
	PCB failure	Replace PCB, call for service
	Load less than 25W at battery mode	Normal condition, no load shutdown function is active
UPS always at battery mode	Power cord lose	Plug in the power cord
	AC fuse burn out	Replace the AC fuse
	PCB failure	Replace PCB, call for service
Back up time to short	Battery not fully charged	Recharge the UPS at least 5 hours
	Battery defective	Replace the battery
Buzzer continuous beeping	Overload	Remove some loads

6. STORAGE

To ensure battery lifetime, please kindly read and also follow below instruction completely.

The UPS is shipped from the factory with its internal battery fully charged, however, some charge maybe lost during shipping and the battery should be recharged prior to use. Plug the UPS into an appropriate power supply and allow the UPS to charge fully by leaving it plugged in for at least 10 hours.

Extend Storage